

TABELLA COMPARATIVA DI EFFICIENZA



**Filtrotecnica
Italiana**

ASHRAE 52.2 MERV	ASHRAE 52.1 EFFICIENZA	EN CLASSE	EN 779 ARRESTANZA	EN 779 EFFICIENZA	EN 1822 EFFICIENZA
1	<20%	G1	50% - 65%	-	-
2	<20%	G2	65% - 80%	-	-
3	<20%			-	-
4	<20%			-	-
5	20%	G3	80% - 90%	-	-
6	20% - 25%			-	-
7	25% - 30%	G4	>90%	-	-
8	30% - 35%			-	-
9	35% - 40%	M5	-	40% - 60%	-
10	50% - 55%				-
11	60% - 65%	M6	-	60% - 80%	-
12	70% - 75%				-
13	80% - 85%	F7	-	80% - 90%	-
14	90% - 95%	F8	-	90% - 95%	-
15	95%	F9	-	>95%	-
16	99%	E10	-	-	<85%
N/A	-	E11	-	-	<95%
N/A	-	E12	-	-	<99,5%
N/A	-	H13	-	-	<99,95%
N/A	-	H14	-	-	<99,995%
N/A	-	U15	-	-	<99,9995%
N/A	-	U16	-	-	<99,99995%
N/A	-	U17	-	-	<99,999995%